



Drinking Water Quality and Compliance
SaskWater – Saskatoon North Treated Water Supply System
Station Number – SK05HH0025
2015 Notice to Consumers

The Water Security Agency (WSA) requires that, at least once each year, waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a waterworks. The following is a summary of the SaskWater – Saskatoon North Treated Water Supply System water quality and sample submission compliance record for the January 1, 2015 to December 31, 2015 time period. This report was completed on April 6, 2016. Readers should refer to the WSA's Municipal Drinking Water Quality Monitoring Guidelines, October 2012, EPB 202 for more information on minimum sample submission requirements and types of samples. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. This system is supplied with water by the City of Saskatoon. Results from these tests can be seen at www.saskatoon.ca. If consumers need to know more about drinking water in Saskatchewan, more detailed information is available from: <http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index-eng.php>.

BACTERIOLOGICAL QUALITY

Parameter	Limit	Regular Samples Required	# of Samples Submitted	# of Positive Regular Submitted
Total Coliform	0 Organisms/100mL	156	159	0
E. Coli	0 Organisms/100m/L	156	159	0
Background Bacteria	Less than 200/100mL	156	159	0

Analysis is performed on a single sample for all parameters mentioned above. All waterworks are required to submit samples for bacteriological water quality; the frequency of monitoring depends on the population served by the waterworks.

WATER DISINFECTION

Chlorine Residual in Transmission System – From Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit (either/or)	Range (mg/L)	Average (mg/L)	# Tests Required	# Tests Submitted	# Adequate Chlorine
Total Chlorine	0.5 mg/L	0.98 – 2.05	1.70	156	159	159

A minimum of 0.5 mg/L Total Chlorine residual is required at all times throughout the distribution system. An adequate chlorine residual is a result that indicates that the chlorine level is above the regulated minimums. A waterworks is required to submit chlorine residual test results on every bacteriological sample they submit.

Total Chlorine Residual for Water in the Distribution System

Parameter	Limit (mg/L)	Range (mg/L)	# Tests Required	# Tests Performed	% Adequate Chlorine
Total Chlorine	At least 0.5	1.34 – 2.28	365	Continuous	100

Minimum 0.5 milligrams per litre (mg/L) total chlorine residual is required for water in a distribution system. Residuals are monitored continuously and tests normally performed on a daily basis by waterworks operators and are to be recorded in operation records.

TURBIDITY

Turbidity in Transmission System – From Test Results Submitted with Bacteriological Samples

Parameter	Limit (NTU)	Range (NTU)	Average (NTU)	# Tests Required	# Tests Performed	# Exceeding Limit
Turbidity	No Standard	0.10 – 0.80	0.19	156	159	0

Turbidity is a measure of water treatment efficiency. Turbidity measures the “clarity” of the drinking water and is generally reported in Nephelometric Turbidity Units (NTU). The turbidity is tested at the same frequency as the bacteriological testing with a bench testing instrument.

CHEMICAL – HEALTH

Water quality analysis was conducted on January 12, 2015 for information only. SaskWater is not required to perform this testing as part of the operating permit. Sample results indicated that the provincial drinking water quality standards were not exceeded.

Parameter	MAC (mg/L)	IMAC (mg/L)	AO* (mg/L)	Sample Results (mg/L)	# of Samples Required	# of Samples Submitted
Aluminum	No Objective			0.0057	0	1
Arsenic	0.010			0.0002	0	1
Barium	1.0			0.041	0	1
Boron		5.0		0.02	0	1
Cadmium	0.005			<0.00001	0	1
Chromium	0.05			<0.0005	0	1
Copper			1.0	0.0009	0	1
Iron			0.3	0.0049	0	1
Lead	0.01			<0.0001	0	1
Manganese			0.05	<0.0005	0	1
Selenium	0.01			0.0005	0	1
Uranium	0.02			0.0012	0	1
Zinc			5	0.0009	0	1

MAC – Maximum Acceptable Concentrations

AO – Aesthetic Objective

IMAC – Interim Maximum Acceptable Concentrations

CHEMICAL – GENERAL

Water quality analysis was conducted on November 24, 2015 for information only. SaskWater is not required to perform this testing as part of the operating permit. Sample results indicated that the provincial drinking water quality standards were not exceeded.

Parameter	MAC	AO*	Sample Results	# of Samples Required	# of Samples Submitted
Total Alkalinity (mg/L)		500	154	0	1
Bicarbonate (mg/L)	No Objective		188	0	1
Calcium (mg/L)	No Objective		45	0	1
Carbonate (mg/L)	No Objective		<1	0	1
Chloride (mg/L)		250	12	0	1
Fluoride (mg/L)	1.5		0.77	0	1
Total Hardness (mg/L)		800	186	0	1
Hydroxide (mg/L)	No Objective		<1	0	1
Magnesium (mg/L)		200	18	0	1
Nitrate (mg/L)	45		0.69	0	1
pH (pH units)		6.5 - 9.0	8.14	0	1
Potassium (mg/L)	No Objective		2.7	0	1
Sodium (mg/L)		300	26	0	1
Specific Conductivity (µs/cm)	No Objective		501	0	1
Sulphate (mg/L)		500	88	0	1
Sum of Ions	No Objective		380	0	1
Total Dissolved Solids (mg/L)		1500	309	0	1

MAC – Maximum Acceptable Concentration

AO – Aesthetic Objective

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO₃, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

CHEMICAL – TRIHALOMETHANES (THM)

Trihalomethanes are formed when chlorine reacts with organic matter in water. The four THM compounds are: chloroform, dibromochloromethane, bromodichloromethane (BCDM) and bromoform. The sum of the concentrations of these four components is referred to as Total Trihalomethanes. The limit for THM is a long term objective based on an annual average of seasonal samples.

Parameter	Limit (mg/L)	Average (mg/L)	# Samples Required	# Samples Submitted
Total Trihalomethanes	0.100	0.051	4	4

More information on water quality and sample submission performance may be obtained from:

SaskWater
200 - 111 Fairford Street East
Moose Jaw SK S6H 1C8
Toll Free: 1-888-230-1111
Fax: 306-694-3207
Email: customerservice@saskwater.com